

Specification Change for Service Tubing

As of July 1, 2010 Harvest-Monrovia Water shall require 1" IPS service tubing for all services to be installed inside a new development. Also 2" schedule 40 PVC shall be required for encasement of all 1" IPS service tubing under the roadway.